



Portable Appliance Testing
You can rely on...

PORTABLE APPLIANCE TESTING CERTIFICATE

Certificate Reference: 0018450

DETAILS OF THE CLIENT

Client and address: Nether Wallop Village Hall, Church Road, Nether Wallop
Postcode: SO20 8ET

DETAILS OF THE INSTALLATION ADDRESS

Installation address: Same as Client Address
Postcode:

DETAILS OF THE CONTRACTOR RESPONSIBLE FOR THE TESTING

Trading Title: Reliance Appliance Testing
Address: 38 Lords Way
Andover
Hampshire
Postcode: SP11 6FQ
Registration Number: SGZ499-1
Telephone Number: 01264 336574

For the inspection and testing of the electrical equipment:

Name: Stewart Wilson Position: Engineer Signature: *[Signature]* Date: 20/04/2021

Test Equipment Used: HPAT600 Serial Number: 258258679

APPLIANCE DETAILS AND TEST RESULTS

| Appliance ID | Test Date | Description | Location | Serial Number | Retest Period | Retest Date | Status |
|--|------------|-----------------------|-------------|------------------|---------------|-------------|--------|
| Site: NetherWallop Village Hall (22 Appliances) | | | | | | | |
| 01 | 21/04/2021 | Urn | Kitchen | Caterlite | 12 | 21/04/2022 | Pass |
| 02 | 21/04/2021 | Fridge | Kitchen | Built in | 12 | 21/04/2022 | Pass |
| Comments: Earth Continuity only | | | | | | | |
| 03 | 21/04/2021 | Fridge/Freezer | Kitchen | Beko | 12 | 21/04/2022 | Pass |
| 04 | 21/04/2021 | Kettle | Kitchen | George | 12 | 21/04/2022 | Pass |
| 05 | 21/04/2021 | Ups | Kitchen | CRT 60 | 12 | 21/04/2022 | Pass |
| 06 | 21/04/2021 | Vacuum Cleaner | Store | Numatic | 12 | 21/04/2022 | Pass |
| 07 | 21/04/2021 | Hot Cupboard | Store | N/A | 12 | 21/04/2022 | Fail |
| Failed Reason: Damaged flex Comments: Fuse removed. | | | | | | | |
| 08 | 21/04/2021 | Lawn Mower | Store | N/A | 12 | 21/04/2022 | Pass |
| 09 | 21/04/2021 | Extension Cable 6-way | Front Store | N/A | 12 | 21/04/2022 | Pass |
| 10 | 21/04/2021 | AC Adapter | Front Store | Bluetooth Socket | 12 | 21/04/2022 | Pass |
| 11 | 21/04/2021 | Amplifier | Front Store | N/A | 12 | 21/04/2022 | Pass |
| 12 | 21/04/2021 | AC Adapter | Front Store | HDMI Switch | 12 | 21/04/2022 | Pass |
| 13 | 21/04/2021 | Mixer | Front Store | N/A | 12 | 21/04/2022 | Pass |
| 14 | 21/04/2021 | Bluray Player | Front Store | N/A | 12 | 21/04/2022 | Pass |
| 15 | 21/04/2021 | AC Adapter | Front Store | Panel Lights | 12 | 21/04/2022 | Pass |
| 16 | 21/04/2021 | Extension Cable 4-way | Front Store | N/A | 12 | 21/04/2022 | Pass |
| 17 | 21/04/2021 | AC Adapter | Front Store | USB | 12 | 21/04/2022 | Pass |
| 18 | 21/04/2021 | AC Adapter | Front Store | BT | 12 | 21/04/2022 | Pass |
| 19 | 21/04/2021 | AC Adapter | Front Store | N/A | 12 | 21/04/2022 | Pass |

APPLIANCE DETAILS AND TEST RESULTS

| Appliance ID | Test Date | Description | Location | Serial Number | Retest Period | Retest Date | Status |
|--|------------|--------------|-------------|--|---------------|-------------|--------|
| Site: NetherWallop Village Hall (Continued) | | | | | | | |
| 20 | 21/04/2021 | AC Adapter | Front Store | N/A | 12 | 21/04/2022 | Pass |
| 21 | 21/04/2021 | Power Supply | Front Store | Defibrillat or | 12 | 21/04/2022 | Pass |
| Comments: Double face plate supply is damaged see photo attached | | | | | | | |
| 22 | 21/04/2021 | Printer | Office | Samsung | 12 | 21/04/2022 | Pass |
| | | | | Total Appliances for Report: 22 | | | |

